



SERVICES

Incorporating ACAL Sound and Lighting

TEL/FAX: 01296 651826

MOBILE: 07885 939842

EMAIL: crownacalsl@aol.com

ELECTRICAL CONTRACTING, MAINTENANCE AND SPECIALIST PROJECT WORK
TO THE SOUND AND LIGHTING INDUSTRY

Portable Appliance Test Certificate

This is to certify that the following items have been tested for electrical safety and have satisfied the requirements of the tests.

CUSTOMER / LOCATION Capture-Me Ref / order #: _____

EQUIPMENT DESCRIPTION / MODEL	ID / SERIAL NO:	VISUAL CHECK/ COMBINED TEST	TEST DATE
LED STRIP	AP001	OK - PASS	23/04/2020
LED STRIP	AP002	OK - PASS	23/04/2020
PRINTER 1	AP003	OK - PASS	23/04/2020
POPCORN MACHINE	AP004	OK - PASS	23/04/2020
LOVE LETTERS	AP005	OK - PASS	23/04/2020
TWIN SPOT LIGHT	AP006	OK - PASS	23/04/2020
LCD TOCH SCREEN	AP007	OK - PASS	23/04/2020
PRINTER 2	AP008	OK - PASS	23/04/2020
CANDY FLOSS MACHINE	AP009	OK - PASS	23/04/2020
LCD 40" TV	AP010	OK - PASS	23/04/2020
LCD 55" TV	AP011	OK - PASS	23/04/2020
EXTENTION LEAD	EX001	OK - PASS	23/04/2020
EXTENTION LEAD	EX002	OK - PASS	23/04/2020
EXTENTION LEAD	EX003	OK - PASS	23/04/2020
EXTENTION LEAD	EX004	OK - PASS	23/04/2020
EXTENTION LEAD	EX005	OK - PASS	23/04/2020
EXTENTION LEAD	EX006	OK - PASS	23/04/2020
EXTENTION LEAD	EX007	OK - PASS	23/04/2020
EXTENTION LEAD	EX008	OK - PASS	23/04/2020
EXTENTION LEAD	EX009	OK - PASS	23/04/2020
EXTENTION LEAD	EX010	OK - PASS	23/04/2020
EXTENTION LEAD	EX011	OK - PASS	23/04/2020
EXTENTION LEAD	EX012	OK - PASS	23/04/2020
IEC POWER CABLE	IEC001	OK - PASS	23/04/2020

Visual Check includes mechanical checks, but no electrical test.

Combined Test also includes earth continuity, Insulation and earth leakage tests.

Test results are recorded and can be viewed if required.

Tested By Tom Crown Signature  Date of Certificate 23/04/2020

Certificate Number 1



SERVICES

Incorporating ACAL Sound and Lighting

TEL/FAX: 01296 651826

MOBILE: 07885 939842

EMAIL: crownacals@aol.com

ELECTRICAL CONTRACTING, MAINTENANCE AND SPECIALIST PROJECT WORK
TO THE SOUND AND LIGHTING INDUSTRY

Portable Appliance Test Certificate

This is to certify that the following items have been tested for electrical safety and have satisfied the requirements of the tests.

CUSTOMER / LOCATION Capture-Me

Ref / order #: _____

EQUIPMENT DESCRIPTION / MODEL	ID / SERIAL NO:	VISUAL CHECK/ COMBINED TEST	TEST DATE
IEC POWER LEAD	IEC002	OK - PASS	23/04/2020
IEC POWER LEAD	IEC003	OK - PASS	23/04/2020
IEC POWER LEAD	IEC004	OK - PASS	23/04/2020
IEC POWER LEAD	IEC005	OK - PASS	23/04/2020
IEC POWER LEAD	IEC006	OK - PASS	23/04/2020
IEC POWER LEAD	IEC007	OK - PASS	23/04/2020
IEC POWER LEAD	IEC008	OK - PASS	23/04/2020
IEC POWER LEAD	IEC009	OK - PASS	23/04/2020
IEC POWER LEAD	IEC010	OK - PASS	23/04/2020
IEC POWER LEAD	IEC011	OK - PASS	23/04/2020
IEC POWER LEAD	IEC012	OK - PASS	23/04/2020
IEC POWER LEAD	IEC013	OK - PASS	23/04/2020
IEC POWER LEAD	IEC014	OK - PASS	23/04/2020
LOW VOLTAGE ADAPTER	LV001	OK - PASS	23/04/2020
LOW VOLTAGE ADAPTER	LV002	OK - PASS	23/04/2020
LOW VOLTAGE ADAPTER	LV003	OK - PASS	23/04/2020
LOW VOLTAGE ADAPTER	LV004	OK - PASS	23/04/2020
LOW VOLTAGE ADAPTER	LV005	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG001	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG002	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG003	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG004	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG005	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG006	OK - PASS	23/04/2020

Visual Check includes mechanical checks, but no electrical test.

Combined Test also includes earth continuity, Insulation and earth leakage tests.

Test results are recorded and can be viewed if required.

Tested By Tom Crown Signature

Date of Certificate 23/04/2020

Certificate Number

2



SERVICES

Incorporating ACAL Sound and Lighting

TEL/FAX: 01296 651826

MOBILE: 07885 939842

EMAIL: crownacals@aol.com

ELECTRICAL CONTRACTING, MAINTENANCE AND SPECIALIST PROJECT WORK TO THE SOUND AND LIGHTING INDUSTRY

Portable Appliance Test Certificate

This is to certify that the following items have been tested for electrical safety and have satisfied the requirements of the tests.

CUSTOMER / LOCATION Capture-Me Ref / order #: _____

EQUIPMENT DESCRIPTION / MODEL	ID / SERIAL NO:	VISUAL CHECK/ COMBINED TEST	TEST DATE
FIG 8 POWER CABLE	FIG006	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG007	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG008	OK - PASS	23/04/2020
FIG 8 POWER CABLE	FIG009	OK - PASS	23/04/2020

Visual Check includes mechanical checks, but no electrical test.
 Combined Test also includes earth continuity, Insulation and earth leakage tests.
 Test results are recorded and can be viewed if required.

Tested By Tom Crown Signature  Date of Certificate 23/04/2019

Certificate Number _____ 3

PORTABLE APPLIANCE TEST RECORD

APPLIANCES

ACElectrical Services

Customer/Location			Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB					Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020		Visual check interval		Combined Test Interval	
<small>(Delete as appropriate)</small>										
Appliance Description	LED STRIP	LED STRIP	PRINTER 1	POPCORN	LOVE LETTERS	TWIP SPOT LT	LCD SCREEN	PRINTER 2	CANDY FLOSS	LCD 40" TV
Serial number							TOUCH			
ID Number	AP001	AP002	AP003	AP004	AP005	AP006	AP007	AP008	AP009	AP010
Class 1 or 2	1	1	1	1	1	2	3	1	1	2
Power or extension Lead?	OK	OK	OK	OK	OK	OK	OK	OK	POWER	POWER
Cable Retention?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Plug Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Fuse Correct? / Size?	N/A	N/A	N/A	OK 13A	N/A	OK 5A	N/A	N/A	OK	OK
Case Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Free of Contamination?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Neons/filters ect. Disconnected	OK	OK	OK	OK	OK	OK	OK	OK	OK	#OK
Test Cable / Adapter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Adapter Resistance (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cable Polarity Test	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	OK	OK
Eart Bond Test (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	OK	OK
Insulation Test (mΩ)	19.9MΩ	19.9Ω	19.9Ω	19.9MΩ	19.9Ω	19.9Ω	N/A	19.9Ω	19.9Ω	N/A
Earth Leakage Test (µA)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
PASS or FAIL	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS
Retest Date	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>
Comments										

PORTABLE APPLIANCE TEST RECORD

APPLIANCES

ACElectrical Services

Customer/Location		Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB					Ref / Phone #			
Tested By	Tom Crown	Date	23/04/2020	Visual check interval		Combined Test Interval				
(Delete as appropriate)										
Appliance Description	LCD 55" TV									
Serial number										
ID Number	AP011									
Class 1 or 2	2									
Power or extension Lead?	POWER									
Cable Retention?	OK									
Plug Intact?	OK									
Fuse Correct? / Size?	OK									
Case Intact?	OK									
Free of Contamination?	OK									
Neons/filters ect. Disconnected	#OK									
Test Cable / Adapter	N/A									
Adapter Resistance (mΩ)	N/A									
Cable Polarity Test	OK									
Eart Bond Test (mΩ)	OK									
Insulation Test (mΩ)	N/A									
Earth Leakage Test (μA)	N/A									
PASS or FAIL	PASS									
Retest Date	23/04/2021									
Signature of Tester	<i>T. Crown</i>									
Comments										

PORTABLE APPLIANCE TEST RECORD

Cable & Extention Leads

ACElectrical Services

Customer/Location		Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB						Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020		Visual check interval		Combined Test Interval	
(Delete as appropriate)										
Cable Description	EX001	EX002	EX003	EX004	EX005	EX006	EX007	EX008	EX009	EX010
ID Number	"	"	"	"	"	"	"	"	"	"
Class 1 or 2	1	1	1	1	1	1	1	1	1	1
Power or extention Lead?	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION	EXTENTION
Cable Retention?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Plug Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Fuse Correct? / Size?	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A	OK 13A
Case Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Free of Contamination?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Neons/filters ect. Disconnected	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Test Cable / Adapter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Adapter Resistance (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cable Polarity Test	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Eart Bond Test (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Insulation Test (mΩ)	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω
Earth Leakage Test (µA)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
PASS or FAIL	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS
Retest Date	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>
Comments										

PORTABLE APPLIANCE TEST RECORD

Cable & Extention Leads

ACElectrical Services

Customer/Location		Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB					Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020	Visual check interval		Combined Test Interval	
(Delete as appropriate)									
Cable Description	EX011	EX012							
ID Number	"	"							
Class 1 or 2	1	1							
Power or extention Lead?	EXTENTION	EXTENTION							
Cable Retention?	OK	OK							
Plug Intact?	OK	OK							
Fuse Correct? / Size?	OK 13A	OK 13A							
Case Intact?	OK	OK							
Free of Contamination?	OK	OK							
Neons/filters ect. Disconnected	N/A	N/A							
Test Cable / Adapter	N/A	N/A							
Adapter Resistance (mΩ)	N/A	N/A							
Cable Polarity Test	OK	OK							
Eart Bond Test (mΩ)	N/A	N/A							
Insulation Test (mΩ)	19.9Ω	19.9Ω							
Earth Leakage Test (μA)	N/A	N/A							
PASS or FAIL	PASS	PASS							
Retest Date	23/04/2021	23/04/2021							
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>							
Comments									

PORTABLE APPLIANCE TEST RECORD

Cable & Extention Leads

ACElectrical Services

Customer/Location		Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB						Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020		Visual check interval		Combined Test Interval	
(Delete as appropriate)										
Cable Description	FIG001	FIG002	FIG003	FIG004	FIG005	FIG006	FIG007	FIG008	FIG009	
ID Number	"	"	"	"	"	"	"	"	"	
Class 1 or 2	1	1	1	1	1	1	1	1	1	
Power or extention Lead?	POWER	POWER	POWER	POWER	POWER	ADAPTER	POWER	POWER	POWER	
Cable Retention?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Plug Intact?	OK 5A	OK 5A	OK 3A	OK 3A	OK 5A	N/A	OK 5A	OK 5A	OK 5A	
Fuse Correct? / Size?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Case Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Free of Contamination?	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Neons/filters ect. Disconnected	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Test Cable / Adapter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Adapter Resistance (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Cable Polarity Test	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Eart Bond Test (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Insulation Test (mΩ)	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	
Earth Leakage Test (µA)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
PASS or FAIL	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	
Retest Date	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	
Comments										

PORTABLE APPLIANCE TEST RECORD

Cable & Extention Leads

ACElectrical Services

Customer/Location			Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB					Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020		Visual check interval		Combined Test Interval	
(Delete as appropriate)										
Cable Description	IEC001	IEC002	IEC003	IEC004	IEC005	IEC006	IEC007	IEC008	IEC009	IEC010
ID Number	"	"	"	"	"	"	"	"	"	"
Class 1 or 2	1	1	1	1	1	1	1	1	1	1
Power or extention Lead?	POWER	POWER	POWER	POWER	POWER	POWER	POWER	POWER	POWER	POWER
Cable Retention?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Plug Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Fuse Correct? / Size?	OK 5A	OK 13A	OK 13A	OK 13A	OK 5A	OK 5A	OK 5A	OK 5A	OK 5A	OK 5A
Case Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Free of Contamination?	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Neons/filters ect. Disconnected	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Test Cable / Adapter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Adapter Resistance (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cable Polarity Test	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
Eart Bond Test (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Insulation Test (mΩ)	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω	19.9Ω
Earth Leakage Test (μA)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
PASS or FAIL	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS
Retest Date	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>
Comments										

PORTABLE APPLIANCE TEST RECORD

Cable & Extention Leads

ACElectrical Services

Customer/Location		Capture-Me, 10 Discovery Street, Aylesbury, Bucks, HP18 0GB						Ref / Phone #		
Tested By	Tom Crown			Date	23/04/2020		Visual check interval		Combined Test Interval	
(Delete as appropriate)										
Cable Description	IEC011	IEC012	IEC013	IEC014	LV001	LV002	LV003	LV004	LV005	
ID Number	"	"	"	"	"	"	"	"	"	
Class 1 or 2	1	1	1	1	3	3	3	3	3	
Power or extention Lead?	POWER	POWER	EXTENTION	EXTENTION	POWER	POWER	POWER	POWER	POWER	
Cable Retention?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Plug Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Fuse Correct? / Size?	OK 5A	OK 5A	OK 5A	OK 5A	N/A	N/A	N/A	N/A	N/A	
Case Intact?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Free of Contamination?	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Neons/filters ect. Disconnected	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Test Cable / Adapter	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Adapter Resistance (mΩ)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Cable Polarity Test	N/A	N/A	N/A	N/A	OK	OK	OK	OK	OK	
Eart Bond Test (mΩ)	OK	OK	OK	OK	OK	OK	OK	OK	OK	
Insulation Test (mΩ)	19.9Ω	19.9Ω	19.9Ω	19.9Ω	N/A	N/A	N/A	N/A	N/A	
Earth Leakage Test (µA)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
PASS or FAIL	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	PASS	
Retest Date	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	23/04/2021	
Signature of Tester	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	<i>T. Crown</i>	
Comments										